

1. Unique identification code of the product-type	UK-WER-0216-02_english
2. Intended use of the construction product as foreseen by the manufacturer, in accordance with the applicable harmonised technical specification	Fire Stopping and Fire Sealing Products for Linear Joint and Gap Seals. The field of application must comply with the content of ETA 20/1137.
3. Name, registered trade name or registered trade mark and contact address of the manufacturer, as required pursuant to Article 11(5) of regulation (EU) No 305/2011	ROCKWOOL® Limited Pencoed, Bridgend, CF35 6NY
4. Name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2) of regulation (EU) No 305/2011	ROCKWOOL® FRANCE S.A.S. 111 rue du Château des Rentiers, 75013 Paris, France. dop.eu@rockwool.com
5. Applicable System or Systems of Assessment and Verification of Constancy of Performance (AVCP)	SYSTEM 1
6. European Assessment Document (EAD) number and date of issue	EAD 350141-00-1106 (Fire Stopping and Fire Sealing Products - Linear Joint and Gap Seals). Issued: September 2017
7. European Technical Assessment (ETA) number and date of issue	ETA 20/1137 Issued: 15th December 2020
8. Technical Assessment Body (TAB) name	ETA-Danmark A/S
9. Notified Body identification number	2531
10. Declared Performances	Please refer to the table below (NPD – No Performance Determined)

EAD Clause	Product characteristics	Assessment of Characteristics
	Basic Works Requirement 2: Safety in case of fire	
2.2.1	Reaction to Fire	B-s1, d0 See ETA 20/1137 Clause 3.2.1 for field of application.
2.2.2	Resistance to Fire	Resistance to fire performance and field of application in accordance with EN13501-2. See ETA 20/1137 Clause 3.2.2 and Annex C
	Basic Works Requirement 3: Hygiene, health and the environment	
2.2.3	Content, emission and/or release of dangerous substances	See ETA 20/1137 Clause 3.3.3
2.2.4	Air permeability (material property)	Tested in accordance with the principles of EN 1026. See ETA 20/1137 Clause 3.3.1
2.2.5	Water permeability (material property)	Tested in accordance with BS EN 1027. See ETA 20/1137 Clause 3.3.2
	Basic Works Requirement 4: Safety and accessibility in use	
2.2.6	Mechanical resistance and stability	NPD
2.2.7	Resistance to impact / movement	NPD
2.2.8	Adhesion	NPD
2.2.12	Durability	Z1: intended for use in internal conditions with humidity ≥85% RH, excluding temperatures below 0°C (no exposure to frost or changing frost-thaw but permanent or alternating condensation).
2.2.13	Movement capability	NPD
2.2.14	Cycling of perimeter seals for curtain walls	NPD
2.2.15	Compression set	NPD
2.2.16	Linear expansion on setting	NPD
	Basic Works Requirement 5: Protection against noise	
2.2.9	Airborne sound insulation	Tested in accordance with EN ISO 10140-2: $R_w (C;Ctr) = 30(-2;-9)$
	Basic Works Requirement 6: Energy economy and heat retention	
2.2.10	Thermal properties	NPD
2.2.11	Water vapour permeability	NPD

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:



Tim Vincent
Head of Technical

At Bridgend on 13th December 2021