

1. Unique identification code of the product-type	UK-WER-0223a-03_english
2. Intended use of the construction product as foreseen by the manufacturer, in accordance with the applicable harmonised technical specification	Fire Stopping and Fire Sealing Products for Penetration Seals. The field of application must comply with the content of ETA 20/1129.
3. Name, registered trade name or registered trade mark and contact address of the manufacturer, as required pursuant to Article 11(5) of regulation (EU) No 305/2011	ROCKWOOL® Limited Pencoed, Bridgend, CF35 6NY
4. Name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2) of regulation (EU) No 305/2011	ROCKWOOL® FRANCE S.A.S. 111 rue du Château des Rentiers, 75013 Paris, France. dop.eu@rockwool.com
5. Applicable System or Systems of Assessment and Verification of Constancy of Performance (AVCP)	SYSTEM 1
6. European Assessment Document (EAD) number and date of issue	EAD 350454-00-1104 (Fire Stopping and Fire Sealing Products - Penetration Seals). Issued: September 2017
7. European Technical Assessment (ETA) number and date of issue	ETA 20/1129 Issued: 15th December 2020
8. Technical Assessment Body (TAB) name	ETA-Danmark A/S
9. Notified Body identification number	2531
10. Declared Performances	Please refer to the table below (NPD – No Performance Determined)

EAD Clause	Product characteristics	Assessment of Characteristics
	Basic Works Requirement 2: Safety in case of fire	
2.2.1	Reaction to Fire	No performance assessed
2.2.2	Resistance to Fire	Resistance to fire performance and field of application in accordance with EN13501-2. See ETA 20/1129 Clause 3.1.2 and Annex C
	Basic Works Requirement 3: Hygiene, health and the environment	
2.2.3	Air permeability	Tested in accordance with the principles of EN 1026. See ETA 20/1129 Clause 3.2.1
2.2.4	Water permeability	NPD
2.2.5	Content, emission and/or release of dangerous substances	See ETA 20/1129 Clause 3.2.2
	Basic Works Requirement 4: Safety and accessibility in use	
2.2.6	Mechanical resistance and stability	NPD
2.2.7	Resistance to impact / movement	NPD
2.2.8	Adhesion	NPD
2.2.9	Durability	Z ₁ : intended for use in internal conditions with humidity ≥85% RH, excluding temperatures below 0°C, without exposure to rain or UV.
	Basic Works Requirement 5: Protection against noise	
2.2.10	Airborne sound insulation	Tested in accordance with EN ISO 10140-2: R _w (C;Ctr) = 38 (-2;-7)
	Basic Works Requirement 6: Energy economy and heat retention	
2.2.11	Thermal properties	NPD
2.2.12	Water vapour permeability	NPD

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:



Tim Vincent
Head of Technical

At Bridgend on 10th December 2021